



**Department of
Education**

Carmen Fariña, Chancellor

Elizabeth A. Rose February 14, 2017

Deputy Chancellor

Division of Operations Dear Families and Staff:

**52 Chambers Street
New York, NY 10007**

212 374 7868 Tel

212 374 5588 Fax

This is a follow up to my December 19 letter outlining the additional measures the New York City Department of Education (DOE) is taking to ensure that the water in New York City schools is safe for students and staff.

On **February 4, 2017**, every potential source of water for drinking or preparing food at **P.S. 175 - Queens** (P.S. 175 The Lynn Gross Discovery School, 64-35 102 Street Queens, NY 11374) was tested for lead. The laboratory results showed elevated levels of lead in **5 of the 113 samples** of water taken and tested from outlets in the building. A more detailed letter related to the testing for lead at P.S. 175 - Queens is attached and complete test results are posted on the DOE website.

In any building where lead test results show even one water outlet above the action level of 15 parts per billion, the DOE will implement its standard response protocol, which includes removing any drinking or cooking water fixture outlet from service, flushing all or part of the system to eliminate water sitting in pipes overnight, replacing equipment and re-testing after the equipment is replaced.

Each affected drinking or cooking water fixture at P.S. 175 - Queens will remain out of service until it is remediated and future testing shows that the water does not have an elevated level of lead. The custodial staff will also continue to flush the P.S. 175 - Queens water systems on Monday mornings before school starts in order to eliminate water that has been stagnant in pipes over the weekend and to ensure safe drinking water is available for students and staff.

Please visit <http://schools.nyc.gov/AboutUs/schools/watersafety.htm> to learn more about the robust protocol we use to ensure the safety of drinking water in each and every school, as well as to look up water test results for their child's school.

We will keep you updated on the remediation work at P.S. 175 - Queens, and thank you for your patience and support.

Sincerely yours,

Elizabeth A. Rose



A NOTICE TO PARENTS, GUARDIANS, AND STAFF
P.S. 175 - Queens
P.S. 175 The Lynn Gross Discovery School
64-35 102 Street Queens, NY 11374
LEAD TESTING OF SCHOOL DRINKING WATER
February 14, 2017

Safe and healthy school environments can foster healthy and successful children. To protect public health, the Public Health Law and New York State Health Department (NYSDOH) regulations require that all public schools and boards of cooperative educational services (BOCES) test lead levels in water from every outlet that is being used, or could potentially be used, for drinking or cooking. If lead is found at any water outlet at levels above 15 parts per billion (ppb), which is equal to 15 micrograms per liter (µg/L), the NYSDOH requires that the school take action to reduce the exposure to lead.

What is first draw testing of school drinking water for lead?

The “on-again, off-again” nature of water use at most schools can raise lead levels in school drinking water. Water that remains in pipes overnight, over a weekend, or over vacation periods stays in contact with lead pipes or lead solder and, as a result, could contain higher levels of lead. This is why schools are required to collect a sample after the water has been sitting in the plumbing system for a certain period of time. This “first draw” sample is likely to show higher levels of lead for that outlet than what you would see if you sampled after using the water continuously. However, even if the first draw sample does not reflect what you would see with continuous usage, it is still important because it can identify outlets that have elevated lead levels.

What are the results of the first draw testing?

Samples Collected on 02/4/2017				
Floor	Function / Space	Room	Fixture Type	Sample Results
01	CLASSROOM	136	COLD WATER FAUCET 1	19 ppb
01	OFFICE	110	COLD WATER FAUCET 1	22.6 ppb
02	CLASSROOM	201	BUBBLER 1	71.4 ppb
02	CLASSROOM	201	COLD WATER FAUCET 1	83.9 ppb
BS	CLASSROOM	B23	COLD WATER FAUCET 1	43 ppb

What is being done in response to the results?

Outlets that tested with lead levels above the action level (15 ppb) at P.S. 175 - Queens have been taken out of service and will be replaced. Each of the affected fixtures will remain out of service until remediation work is completed and future testing provides results below the action level.

What are the health effects of lead?

Lead is a metal that can harm children and adults when it gets into their bodies. Lead is a known neurotoxin, particularly harmful to the developing brain and nervous system of children under 6 years old. Lead can harm a young child's growth, behavior, and ability to learn. Lead exposure during pregnancy may contribute to low birth weight and developmental delays in infants. There are many sources of lead exposure in the environment, and it is important to reduce all lead exposures as much as possible. Water testing helps identify and correct possible sources of lead that contribute to exposure from drinking water.

What are the other sources of lead exposure?

Lead is a metal that has been used for centuries for many purposes, resulting in widespread distribution in the environment. Major sources of lead exposure include lead-based paint in older housing, and lead that built up over decades in soil and dust due to historical use of lead in gasoline, paint, and manufacturing. Lead can also be found in a



**Department of
Education**

Carmen Fariña, Chancellor

number of consumer products, including certain types of pottery, pewter, brass fixtures, foods, plumbing materials, and cosmetics. Lead seldom occurs naturally in water supplies but drinking water could become a possible source of lead exposure if the building's plumbing contains lead. The primary source of lead exposure for most children with elevated blood-lead levels is lead-based paint.

Should your child be tested for lead?

The risk to an individual child from past exposure to elevated lead in drinking water depends on many factors; for example, a child's age, weight, amount of water consumed, and the amount of lead in the water. Children may also be exposed to other significant sources of lead including paint, soil and dust. Since blood lead testing is the only way to determine a child's blood lead level, parents should discuss their child's health history with their child's physician to determine if blood lead testing is appropriate. Pregnant women or women of childbearing age should also consider discussing this matter with their physician.

Do elevated lead levels in school drinking water pose a serious risk to students and staff?

The risk to students and staff is low for many reasons. The elevated lead levels identified by the recent round of water testing are not likely to represent the levels seen throughout the day. The recent testing was conducted on water that had remained in pipes overnight. The lead concentration drops sharply after the first use of the day as stagnant water is cleared from the pipes and new, fresh water is brought in from the water main – which is virtually lead-free. In addition, for most students and staff, the amount of water consumed from a school water source during a school day is likely to be small when compared to total daily water consumption. Many of the elevated water samples came from fixtures that are not typically used for drinking, including bathrooms, slop sinks, and laboratories. Given all of these factors it is unlikely that these elevations represent conditions that would pose a health risk, however, if a person drinks sufficiently large quantities of water at those high levels over long periods of time, the risk increases. Nonetheless, if you are concerned about exposure to lead, talk to your doctor about having you or your child tested for lead poisoning.

Who is at risk for lead poisoning?

Children under 3 years of age are the most susceptible and vulnerable to the health effects of lead. Lead also poses a risk to the developing fetus. Exposure to lead may interfere with a child's growth and development.

What do we know about rates of lead poisoning in NYC children?

Rates of lead poisoning among NYC children have been falling. In 2015, 5,371 New York City children younger than 6 years of age were identified with blood lead levels of 5 mcg/dL or greater. This represents an 18% decline from 2014 when there were 6,550 children with blood lead levels of 5 mcg/dL or greater, and an 86% decline since 2005 when there were 37,344 children with blood lead levels of 5mcg/dL or greater.

Additional Resources

For more information regarding the testing program or sampling results go to:

<http://schools.nyc.gov/AboutUs/schools/watersafety.htm>

For information about lead in school drinking water, go to:

http://www.health.ny.gov/environmental/water/drinking/lead/lead_testing_of_school_drinking_water.htm

<http://www.p12.nysed.gov/facplan/LeadTestinginSchoolDrinkingWater.html>

For information about NYS Department of Health Lead Poisoning Prevention, go to:

<http://www.health.ny.gov/environmental/lead/>

For more information on blood lead testing and ways to reduce your child's risk of exposure to lead, see "What Your Child's Blood Lead Test Means":

<http://www.health.ny.gov/publications/2526/> (available in ten languages).



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Jon Vafiadis
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

2/13/2017

Phone: (718) 383-2626
Fax: (718) 383-7780

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 2/7/2017. The results are tabulated on the attached data pages for the following client designated project:

**Q175/ P.S. 175 - Queens/ 64-35 102 Street/ Queens/ PEI Project #:
2181-17-0439**

The reference number for these samples is EMSL Order #011701024. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 187

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011701024
 CustomerID: PCIS63
 CustomerPO:
 ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 02/07/17 7:00 AM

Project: Q175/ P.S. 175 - Queens/ 64-35 102 Street/ Queens/ PEI Project #: 2181-17-0439

Analytical Results

Client Sample Description 1CQ175BSBR000B13.1F-001 **Collected:** 2/4/2017 **Lab ID:** 0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.05	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ175BSBR000B33.1F-002 **Collected:** 2/4/2017 **Lab ID:** 0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.30	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ175BSBB000B28.1F-004 **Collected:** 2/4/2017 **Lab ID:** 0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ175BSBB000B28.2F-005 **Collected:** 2/4/2017 **Lab ID:** 0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ175BSCFBASEME.1B-006 **Collected:** 2/4/2017 **Lab ID:** 0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ175BSCFBASEME.2B-007 **Collected:** 2/4/2017 **Lab ID:** 0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ175BSCFBASEME.1F-008 **Collected:** 2/4/2017 **Lab ID:** 0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.25	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011701024
 CustomerID: PCIS63
 CustomerPO:
 ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 02/07/17 7:00 AM

Project: Q175/ P.S. 175 - Queens/ 64-35 102 Street/ Queens/ PEI Project #: 2181-17-0439

Analytical Results

Client Sample Description 1CQ175BSCFBASEME.2F-009 **Collected:** 2/4/2017 **Lab ID:** 0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.12	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ175BSCFBASEME.3F-010 **Collected:** 2/4/2017 **Lab ID:** 0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.12	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ175BSCFBASEME.4F-011 **Collected:** 2/4/2017 **Lab ID:** 0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.62	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ175BSCR000B23.1F-012 **Collected:** 2/4/2017 **Lab ID:** 0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	43.0	1.00	µg/L	2/9/2017	KB	2/10/2017	BB

Client Sample Description 1CQ175BSGB000B24.1F-013 **Collected:** 2/4/2017 **Lab ID:** 0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ175BSGB000B24.2F-014 **Collected:** 2/4/2017 **Lab ID:** 0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ175BSKIBASEME.1F-015 **Collected:** 2/4/2017 **Lab ID:** 0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701024

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 02/07/17 7:00 AM

Project: Q175/ P.S. 175 - Queens/ 64-35 102 Street/ Queens/ PEI Project #: 2181-17-0439

Analytical Results

Client Sample Description 1CQ175BSKIBASEME.2F-016 **Collected:** 2/4/2017 **Lab ID:** 0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ175BSLR000B21.1F-017 **Collected:** 2/4/2017 **Lab ID:** 0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ175MZST0000MZ.1F-018 **Collected:** 2/4/2017 **Lab ID:** 0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.56	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501BR000105.1F-019 **Collected:** 2/4/2017 **Lab ID:** 0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.91	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501BR000126.1F-020 **Collected:** 2/4/2017 **Lab ID:** 0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.77	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501BR000133.1F-021 **Collected:** 2/4/2017 **Lab ID:** 0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.40	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501BB000124.1F-022 **Collected:** 2/4/2017 **Lab ID:** 0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701024

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 02/07/17 7:00 AM

Project: Q175/ P.S. 175 - Queens/ 64-35 102 Street/ Queens/ PEI Project #: 2181-17-0439

Analytical Results

Client Sample Description 1CQ17501BB000124.2F-023 **Collected:** 2/4/2017 **Lab ID:** 0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501BB01STFL.1F-024 **Collected:** 2/4/2017 **Lab ID:** 0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501CR000101.1B-025 **Collected:** 2/4/2017 **Lab ID:** 0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.36	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501CR000101.1F-026 **Collected:** 2/4/2017 **Lab ID:** 0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.65	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501CR000102.1B-027 **Collected:** 2/4/2017 **Lab ID:** 0026

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.83	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501CR000102.1F-028 **Collected:** 2/4/2017 **Lab ID:** 0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.74	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501CR000104.1B-029 **Collected:** 2/4/2017 **Lab ID:** 0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.23	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701024

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 02/07/17 7:00 AM

Project: Q175/ P.S. 175 - Queens/ 64-35 102 Street/ Queens/ PEI Project #: 2181-17-0439

Analytical Results

Client Sample Description 1CQ17501CR000104.1F-030 **Collected:** 2/4/2017 **Lab ID:** 0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.65	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501CR000114.1B-031 **Collected:** 2/4/2017 **Lab ID:** 0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.48	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501CR000114.1F-032 **Collected:** 2/4/2017 **Lab ID:** 0031

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.73	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501CR000116.1B-033 **Collected:** 2/4/2017 **Lab ID:** 0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.49	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501CR000116.1F-034 **Collected:** 2/4/2017 **Lab ID:** 0033

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.79	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501CR000120.1B-035 **Collected:** 2/4/2017 **Lab ID:** 0034

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501CR000120.1F-036 **Collected:** 2/4/2017 **Lab ID:** 0035

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.41	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701024

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 02/07/17 7:00 AM

Project: Q175/ P.S. 175 - Queens/ 64-35 102 Street/ Queens/ PEI Project #: 2181-17-0439

Analytical Results

Client Sample Description 1CQ17501CR000121.1B-037 **Collected:** 2/4/2017 **Lab ID:** 0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.34	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501CR000121.1F-038 **Collected:** 2/4/2017 **Lab ID:** 0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.36	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501CR000123.1B-039 **Collected:** 2/4/2017 **Lab ID:** 0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.15	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501CR000123.1F-040 **Collected:** 2/4/2017 **Lab ID:** 0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.74	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501CR000132.1B-041 **Collected:** 2/4/2017 **Lab ID:** 0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.04	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501CR000132.1F-042 **Collected:** 2/4/2017 **Lab ID:** 0041

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.38	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501CR000134.1B-043 **Collected:** 2/4/2017 **Lab ID:** 0042

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.59	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701024

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 02/07/17 7:00 AM

Project: Q175/ P.S. 175 - Queens/ 64-35 102 Street/ Queens/ PEI Project #: 2181-17-0439

Analytical Results

Client Sample Description 1CQ17501CR000134.1F-044 **Collected:** 2/4/2017 **Lab ID:** 0043

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.42	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501CR000136.1B-045 **Collected:** 2/4/2017 **Lab ID:** 0044

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.72	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501CR000136.1F-046 **Collected:** 2/4/2017 **Lab ID:** 0045

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	19.0	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501GB000112.1F-047 **Collected:** 2/4/2017 **Lab ID:** 0046

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.10	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501GB000112.2F-048 **Collected:** 2/4/2017 **Lab ID:** 0047

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.41	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501GB01STFL.1F-049 **Collected:** 2/4/2017 **Lab ID:** 0048

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.30	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501MO000107.1F-050 **Collected:** 2/4/2017 **Lab ID:** 0049

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.32	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701024

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 02/07/17 7:00 AM

Project: Q175/ P.S. 175 - Queens/ 64-35 102 Street/ Queens/ PEI Project #: 2181-17-0439

Analytical Results

Client Sample Description 1CQ17501MO000107.2F-051 **Collected:** 2/4/2017 **Lab ID:** 0050

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.66	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501MO000107.3F-052 **Collected:** 2/4/2017 **Lab ID:** 0051

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.19	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501OF000103.1F-053 **Collected:** 2/4/2017 **Lab ID:** 0052

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.64	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501OF000106.1F-054 **Collected:** 2/4/2017 **Lab ID:** 0053

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.47	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501OF000110.1F-055 **Collected:** 2/4/2017 **Lab ID:** 0054

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	22.6	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17501OF000130.1F-056 **Collected:** 2/4/2017 **Lab ID:** 0055

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.23	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17502BB000225.1F-057 **Collected:** 2/4/2017 **Lab ID:** 0056

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701024

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 02/07/17 7:00 AM

Project: Q175/ P.S. 175 - Queens/ 64-35 102 Street/ Queens/ PEI Project #: 2181-17-0439

Analytical Results

Client Sample Description 1CQ17502BB000225.2F-058 **Collected:** 2/4/2017 **Lab ID:** 0057

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17502BB000225.3F-059 **Collected:** 2/4/2017 **Lab ID:** 0058

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17502CR000201.1B-060 **Collected:** 2/4/2017 **Lab ID:** 0059

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	71.4	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17502CR000201.1F-061 **Collected:** 2/4/2017 **Lab ID:** 0060

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	83.9	1.00	µg/L	2/8/2017	AE	2/8/2017	BB

Client Sample Description 1CQ17502CR000202.1B-062 **Collected:** 2/4/2017 **Lab ID:** 0061

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.11	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000202.1F-063 **Collected:** 2/4/2017 **Lab ID:** 0062

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.34	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000203.1B-064 **Collected:** 2/4/2017 **Lab ID:** 0063

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701024

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 02/07/17 7:00 AM

Project: Q175/ P.S. 175 - Queens/ 64-35 102 Street/ Queens/ PEI Project #: 2181-17-0439

Analytical Results

Client Sample Description 1CQ17502CR000203.1F-065 **Collected:** 2/4/2017 **Lab ID:** 0064

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000204.1B-066 **Collected:** 2/4/2017 **Lab ID:** 0065

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.06	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000204.1F-067 **Collected:** 2/4/2017 **Lab ID:** 0066

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.40	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000205.1F-068 **Collected:** 2/4/2017 **Lab ID:** 0067

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.93	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000206.1B-069 **Collected:** 2/4/2017 **Lab ID:** 0068

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.27	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000206.1F-070 **Collected:** 2/4/2017 **Lab ID:** 0069

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.71	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000214.1B-071 **Collected:** 2/4/2017 **Lab ID:** 0070

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.90	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701024

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 02/07/17 7:00 AM

Project: Q175/ P.S. 175 - Queens/ 64-35 102 Street/ Queens/ PEI Project #: 2181-17-0439

Analytical Results

Client Sample Description 1CQ17502CR000214.1F-072 **Collected:** 2/4/2017 **Lab ID:** 0071

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.49	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000216.1B-073 **Collected:** 2/4/2017 **Lab ID:** 0072

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.14	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000216.1F-074 **Collected:** 2/4/2017 **Lab ID:** 0073

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.57	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000220.1B-075 **Collected:** 2/4/2017 **Lab ID:** 0074

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.71	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000220.1F-076 **Collected:** 2/4/2017 **Lab ID:** 0075

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.56	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000221.1B-077 **Collected:** 2/4/2017 **Lab ID:** 0076

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.64	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000221.1F-078 **Collected:** 2/4/2017 **Lab ID:** 0077

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.07	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701024

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 02/07/17 7:00 AM

Project: Q175/ P.S. 175 - Queens/ 64-35 102 Street/ Queens/ PEI Project #: 2181-17-0439

Analytical Results

Client Sample Description 1CQ17502CR000222.1B-079 **Collected:** 2/4/2017 **Lab ID:** 0078

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.21	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000222.1F-080 **Collected:** 2/4/2017 **Lab ID:** 0079

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.03	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000223.1B-081 **Collected:** 2/4/2017 **Lab ID:** 0080

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.72	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000223.1F-082 **Collected:** 2/4/2017 **Lab ID:** 0081

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.55	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000232.1B-083 **Collected:** 2/4/2017 **Lab ID:** 0082

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.97	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000232.1F-084 **Collected:** 2/4/2017 **Lab ID:** 0083

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.79	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000234.1B-085 **Collected:** 2/4/2017 **Lab ID:** 0084

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701024

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 02/07/17 7:00 AM

Project: Q175/ P.S. 175 - Queens/ 64-35 102 Street/ Queens/ PEI Project #: 2181-17-0439

Analytical Results

Client Sample Description 1CQ17502CR000234.1F-086 **Collected:** 2/4/2017 **Lab ID:** 0085

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.17	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000236.1B-087 **Collected:** 2/4/2017 **Lab ID:** 0086

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.14	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502CR000236.1F-088 **Collected:** 2/4/2017 **Lab ID:** 0087

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.42	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502GB000212.1F-089 **Collected:** 2/4/2017 **Lab ID:** 0088

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502GY02NDFL.1B-090 **Collected:** 2/4/2017 **Lab ID:** 0089

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502GY02NDFL.1F-092 **Collected:** 2/4/2017 **Lab ID:** 0090

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.19	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17502TC000230.1F-097 **Collected:** 2/4/2017 **Lab ID:** 0091

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.08	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701024

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 02/07/17 7:00 AM

Project: Q175/ P.S. 175 - Queens/ 64-35 102 Street/ Queens/ PEI Project #: 2181-17-0439

Analytical Results

Client Sample Description 1CQ17503BB000325.1F-098 **Collected:** 2/4/2017 **Lab ID:** 0092

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.10	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17503BB000325.2F-099 **Collected:** 2/4/2017 **Lab ID:** 0093

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.84	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17503CR000301.1B-103 **Collected:** 2/4/2017 **Lab ID:** 0094

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.76	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17503CR000301.1F-104 **Collected:** 2/4/2017 **Lab ID:** 0095

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.69	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17503CR000302.1B-105 **Collected:** 2/4/2017 **Lab ID:** 0096

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.20	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17503CR000302.1F-106 **Collected:** 2/4/2017 **Lab ID:** 0097

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.11	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17503CR000303.1B-107 **Collected:** 2/4/2017 **Lab ID:** 0098

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.71	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701024

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 02/07/17 7:00 AM

Project: Q175/ P.S. 175 - Queens/ 64-35 102 Street/ Queens/ PEI Project #: 2181-17-0439

Analytical Results

Client Sample Description 1CQ17503CR000303.1F-108 **Collected:** 2/4/2017 **Lab ID:** 0099

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.85	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17503CR000304.1B-109 **Collected:** 2/4/2017 **Lab ID:** 0100

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17503CR000304.1F-110 **Collected:** 2/4/2017 **Lab ID:** 0101

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.52	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17503CR000306.1B-111 **Collected:** 2/4/2017 **Lab ID:** 0102

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.90	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17503CR000306.1F-112 **Collected:** 2/4/2017 **Lab ID:** 0103

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.54	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17503CR000320.1B-113 **Collected:** 2/4/2017 **Lab ID:** 0104

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.34	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17503CR000320.1F-114 **Collected:** 2/4/2017 **Lab ID:** 0105

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.56	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701024

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 02/07/17 7:00 AM

Project: Q175/ P.S. 175 - Queens/ 64-35 102 Street/ Queens/ PEI Project #: 2181-17-0439

Analytical Results

Client Sample Description 1CQ17503CR000321.1B-115 **Collected:** 2/4/2017 **Lab ID:** 0106

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.37	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17503CR000321.1F-116 **Collected:** 2/4/2017 **Lab ID:** 0107

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.90	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17503CR000322.1B-117 **Collected:** 2/4/2017 **Lab ID:** 0108

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.11	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17503CR000322.1F-118 **Collected:** 2/4/2017 **Lab ID:** 0109

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.15	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17503CR000324.1B-119 **Collected:** 2/4/2017 **Lab ID:** 0110

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.67	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17503CR000324.1F-120 **Collected:** 2/4/2017 **Lab ID:** 0111

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.17	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Client Sample Description 1CQ17503GB000305.1F-121 **Collected:** 2/4/2017 **Lab ID:** 0112

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701024

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Jon Vafiadis**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 02/07/17 7:00 AM

Project: Q175/ P.S. 175 - Queens/ 64-35 102 Street/ Queens/ PEI Project #: 2181-17-0439

Analytical Results

Client Sample Description 1CQ17503GB000305.2F-122 **Collected:** 2/4/2017 **Lab ID:** 0113

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.32	1.00	µg/L	2/9/2017	AE	2/10/2017	EG

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

CONSULTANT INFORMATION













Name: Precision Environmental Inc.
 Address: 36-15A 23rd Street, LIC, NY 11106
 Project Manager: Jon Vafiadis
 PEI Project#: 2181-17-0439

PROJECT INFORMATION

BLDG ID: Q175
 BLDG Name: P.S. 175 - QUEENS
 BLDG Address: 64-35 102 STREET
 WO # Queens

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

		(ppb)				(ppb)	
1ST COC Q175 BS FL ADULT BATHROOM 000B13 COLD WATER FAUCET 1  DATE 2-4-17 TIME 0900			I O T M	1	1ST COC Q175 BS FL CAFETERIA BASEME COLD WATER FAUCET 1  DATE 2-4-17 TIME 0741		I O T M 7
1ST COC Q175 BS FL ADULT BATHROOM 000B33 COLD WATER FAUCET 1  DATE 2-4-17 TIME 0715			I O T M	2	1ST COC Q175 BS FL CAFETERIA BASEME COLD WATER FAUCET 2  DATE 2-4-17 TIME 0744		I O T M 8
1ST COC Q175 BS FL BOYS BATHROOM 000B28 COLD WATER FAUCET 1  DATE 2-4-17 TIME 0925			I O T M	3	1ST COC Q175 BS FL CAFETERIA BASEME COLD WATER FAUCET 3  DATE 2-4-17 TIME 0747		I O T M 9
1ST COC Q175 BS FL BOYS BATHROOM 000B28 COLD WATER FAUCET 2  DATE 2-4-17 TIME 0728			I O T M	4	1ST COC Q175 BS FL CAFETERIA BASEME COLD WATER FAUCET 4  DATE 2-4-17 TIME 0750		I O T M 10
1ST COC Q175 BS FL CAFETERIA BASEME BUBBLER 1  DATE 2-4-17 TIME 0733			I O T M	5	1ST COC Q175 BS FL CLASSROOM 000B23 COLD WATER FAUCET 1  DATE 2-4-17 TIME 0755		I O T M 11
1ST COC Q175 BS FL CAFETERIA BASEME BUBBLER 2  DATE 2-4-17 TIME 0736			I O T M	6	1ST COC Q175 BS FL GIRLS BATHROOM 000B24 COLD WATER FAUCET 1  DATE 2-4-17 TIME 0800		I O T M 12

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1 <i>S. Hussain</i>	<i>Jenny Jackson</i>	2/06/17	2017 FEB - 6 PM 3:30
2 <i>Hussain</i>	<i>Aminwade</i>		EMSC RECEIVED
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name: <i>EMSC</i>	Method of Analysis: <i>2008</i>
Analyzed By: <i>Barbara Biddle</i>	Date: <i>2/8/2017/2/10/2017</i>
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative:
	Sample Size: 250 mL

rec'd by Steven Lopez on 2/7/17 @ 7:00am 20.9

CONSULTANT INFORMATION













Name: Precision Environmental Inc.
 Address: 36-15A 23rd Street, LIC, NY 11106
 Project Manager: Jon Vafiadis
 PEI Project#: 2181-17-0439

PROJECT INFORMATION

BLDG ID: Q175
 BLDG Name: P.S. 175 - QUEENS
 BLDG Address: 64-35 102 STREET
 WO # Queens

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

(ppb)				(ppb)				
	1ST COC Q175 BS FL GIRLS BATHROOM 000B24 COLD WATER FAUCET 2  DATE 2-4-17 TIME 0853		I O T M	13		1ST COC Q175 01 FL ADULT BATHROOM 000126 COLD WATER FAUCET 1  DATE 2-4-17 TIME 0831	I O T M	19
	1ST COC Q175 BS FL KITCHEN BASEME COLD WATER FAUCET 1  DATE 2-4-17 TIME 0808		I O T M	14		1ST COC Q175 01 FL ADULT BATHROOM 000133 COLD WATER FAUCET 1  DATE 2-4-17 TIME 0836	I O T M	20
	1ST COC Q175 BS FL KITCHEN BASEME COLD WATER FAUCET 2  DATE 2-4-17 TIME 0844		I O T M	15		1ST COC Q175 01 FL BOYS BATHROOM 000124 COLD WATER FAUCET 1  DATE 2-4-17 TIME 0844	I O T M	21
	1ST COC Q175 BS FL LOCKER ROOM 000B21 COLD WATER FAUCET 1  DATE 2-4-17 TIME 0816		I O T M	16		1ST COC Q175 01 FL BOYS BATHROOM 000124 COLD WATER FAUCET 2  DATE 2-4-17 TIME 0844	I O T M	22
	1ST COC Q175 MZ FL STAIRWELL 0000MZ COLD WATER FAUCET 1  DATE 2-4-17 TIME 0821		I O T M	17		1ST COC Q175 01 FL BOYS BATHROOM 01STFL COLD WATER FAUCET 1  DATE 2-4-17 TIME 0849	I O T M	23
	1ST COC Q175 01 FL ADULT BATHROOM 000105 COLD WATER FAUCET 1  DATE 2-4-17 TIME 0828		I O T M	18		1ST COC Q175 01 FL CLASSROOM 000101 BUBBLER 1  DATE 2-4-17 TIME 0854	I O T M	24

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1 Hussain <i>Hussain</i>	<i>Demoy Barson</i>	<i>2/4/17</i>	<i>3:32P</i>
2 Hussain <i>Hussain</i>	<i>Demoy Barson</i>		
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name: <u>EMSL</u>	Method of Analysis: <u>200.8</u>
Analyzed By: <u>Barbara Biddle</u>	Date: <u>2/8/2017</u>
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Time: _____
	Preservative: _____
	Sample Size: 250 mL

rec'd by Steven Lopez on 2/7/17 @ 7:00am 20.9

CONSULTANT INFORMATION

Name: Precision Environmental Inc.
 Address: 36-15A 23rd Street, LIC, NY 11106
 Project Manager: Jon Vafiadis
 PEI Project#: 2181-17-0439

PROJECT INFORMATION

BLDG ID: Q175
 BLDG Name: P.S. 175 - QUEENS
 BLDG Address: 64-35 102 STREET
 WO # Queens

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

(ppb)				(ppb)			
1ST COC Q175 01 FL CLASSROOM 000101 COLD WATER FAUCET 1 DATE <u>2-4-17</u> TIME <u>0857</u>			I O T M 25	1ST COC Q175 01 FL CLASSROOM 000114 COLD WATER FAUCET 1 DATE <u>2-4-17</u> TIME <u>0921</u>			I O T M 31
1ST COC Q175 01 FL CLASSROOM 000102 BUBBLER 1 DATE <u>2-4-17</u> TIME <u>0902</u>			I O T M 26	1ST COC Q175 01 FL CLASSROOM 000116 BUBBLER 1 DATE <u>2-4-17</u> TIME <u>0928</u>			I O T M 32
1ST COC Q175 01 FL CLASSROOM 000102 COLD WATER FAUCET 1 DATE <u>2-4-17</u> TIME <u>0905</u>			I O T M 27	1ST COC Q175 01 FL CLASSROOM 000116 COLD WATER FAUCET 1 DATE <u>2-4-17</u> TIME <u>0929</u>			I O T M 33
1ST COC Q175 01 FL CLASSROOM 000104 BUBBLER 1 DATE <u>2-4-17</u> TIME <u>0900</u>			I O T M 28	1ST COC Q175 01 FL CLASSROOM 000120 BUBBLER 1 DATE <u>2-4-17</u> TIME <u>0934</u>			I O T M 34
1ST COC Q175 01 FL CLASSROOM 000104 COLD WATER FAUCET 1 DATE <u>2-4-17</u> TIME <u>0913</u>			I O T M 29	1ST COC Q175 01 FL CLASSROOM 000120 COLD WATER FAUCET 1 DATE <u>2-4-17</u> TIME <u>0937</u>			I O T M 35
1ST COC Q175 01 FL CLASSROOM 000114 BUBBLER 1 DATE <u>2-4-17</u> TIME <u>0918</u>			I O T M 30	1ST COC Q175 01 FL CLASSROOM 000121 BUBBLER 1 DATE <u>2-4-17</u> TIME <u>0942</u>			I O T M 36

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	2017 FEB -6 PM 3:32 RECEIVED HANHAT ANH LAM
1 <u>SKUMIBU Hussain</u>	<u>Demoy Jackson</u>	<u>2/6/17</u>	
2 <u>Hussein Akimwande</u>			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name: <u>EMSL</u>	Method of Analysis: <u>200-8</u>
Analyzed By: <u>Barbara Biddle</u>	Date: <u>2/8/2017</u> Time: _____
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: _____ Sample Size: 250 mL

rec'd by Steven Japes on 2/7/17 @ 7:00am 20.9

CONSULTANT INFORMATION













Name: Precision Environmental Inc.
 Address: 36-15A 23rd Street, LIC, NY 11106
 Project Manager: Jon Vafiadis
 PEI Project#: 2181-17-0439

PROJECT INFORMATION

BLDG ID: Q175
 BLDG Name: P.S. 175 - QUEENS
 BLDG Address: 64-35 102 STREET
 WO # Queens

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

	(ppb)			(ppb)	
1ST COC Q175 01 FL CLASSROOM 000121 COLD WATER FAUCET 1  DATE 2-4-17 TIME 0945		I O T M	37	1ST COC Q175 01 FL CLASSROOM 000134 COLD WATER FAUCET 1  DATE 2-4-17 TIME 1009	I O T M 43
1ST COC Q175 01 FL CLASSROOM 000123 BUBBLER 1  DATE 2-4-17 TIME 0950		I O T M	38	1ST COC Q175 01 FL CLASSROOM 000136 BUBBLER 1  DATE 2-4-17 TIME 1014	I O T M 44
1ST COC Q175 01 FL CLASSROOM 000123 COLD WATER FAUCET 1  DATE 2-4-17 TIME 0953		I O T M	39	1ST COC Q175 01 FL CLASSROOM 000136 COLD WATER FAUCET 1  DATE 2-4-17 TIME 1017	I O T M 45
1ST COC Q175 01 FL CLASSROOM 000132 BUBBLER 1  DATE 2-4-17 TIME 0958		I O T M	40	1ST COC Q175 01 FL GIRLS BATHROOM 000112 COLD WATER FAUCET 1  DATE 2-4-17 TIME 1022	I O T M 46
1ST COC Q175 01 FL CLASSROOM 000132 COLD WATER FAUCET 1  DATE 2-4-17 TIME 1001		I O T M	41	1ST COC Q175 01 FL GIRLS BATHROOM 000112 COLD WATER FAUCET 2  DATE 2-4-17 TIME 1025	I O T M 47
1ST COC Q175 01 FL CLASSROOM 000134 BUBBLER 1  DATE 2-4-17 TIME 1006		I O T M	42	1ST COC Q175 01 FL GIRLS BATHROOM 01STFL COLD WATER FAUCET 1  DATE 2-4-17 TIME 1030	I O T M 48

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1 <u>Stuvarson</u> <u>Cassara</u>	<u>Jonny Carter</u>	<u>2/06/17</u>	<u>3:30P</u>
2 <u>Hussen</u> <u>Abinwande</u>			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name: <u>EMSL</u>	Method of Analysis: <u>200-8</u>
Analyzed By: <u>Barbara Bidle</u>	Date: <u>2/8/2017</u> Time: <u></u>
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: <u></u> Sample Size: 250 mL

rec'd by Steven Lopez on 2/7/17 @ 7:00am 20-9

CONSULTANT INFORMATION













Name: Precision Environmental Inc.
 Address: 36-15A 23rd Street, LIC, NY 11106
 Project Manager: Jon Vafiadis
 PEI Project#: 2181-17-0439

PROJECT INFORMATION

BLDG ID: Q175
 BLDG Name: P.S. 175 - QUEENS
 BLDG Address: 64-35 102 STREET
 WO # Queens

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

	(ppb)			(ppb)	
1ST COC Q175 01 FL MEDICAL OFFICE 000107 COLD WATER FAUCET 1  DATE 2-4-17 TIME 1035		I O T M	49	1ST COC Q175 01 FL OFFICE 000130 COLD WATER FAUCET 1  DATE 2-4-17 TIME 1100	I O T M 55
1ST COC Q175 01 FL MEDICAL OFFICE 000107 COLD WATER FAUCET 2  DATE 2-4-17 TIME 1038		I O T M	50	1ST COC Q175 02 FL BOYS BATHROOM 000225 COLD WATER FAUCET 1  DATE 2-4-17 TIME 1105	I O T M 52
1ST COC Q175 01 FL MEDICAL OFFICE 000107 COLD WATER FAUCET 3  DATE 2-4-17 TIME 1041		I O T M	51	1ST COC Q175 02 FL BOYS BATHROOM 000225 COLD WATER FAUCET 2  DATE 2-4-17 TIME 1108	I O T M 57
1ST COC Q175 01 FL OFFICE 000103 COLD WATER FAUCET 1  DATE 2-4-17 TIME 1046		I O T M	52	1ST COC Q175 02 FL BOYS BATHROOM 000225 COLD WATER FAUCET 3  DATE 2-4-17 TIME 1111	I O T M 58
1ST COC Q175 01 FL OFFICE 000106 COLD WATER FAUCET 1  DATE 2-4-17 TIME 1051		I O T M	53	1ST COC Q175 02 FL CLASSROOM 000201 BUBBLER 1  DATE 2-4-17 TIME 1116	I O T M 59
1ST COC Q175 01 FL OFFICE 000110 COLD WATER FAUCET 1  DATE 2-4-17 TIME 1055		I O T M	54	1ST COC Q175 02 FL CLASSROOM 000201 COLD WATER FAUCET 1  DATE 2-4-17 TIME 1119	I O T M 60

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1 <i>Stavros Hussain</i>	<i>Henry B</i>	<i>2/6/17</i>	<i>3:32 PM</i>
2 <i>Hussein Akinwande</i>			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name: <u>EMSL</u>	Method of Analysis: <u>200.8</u>
Analyzed By: <u>Barbra Biddle</u>	Date: <u>2/8/2017</u> Time: _____
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: _____ Sample Size: 250 mL

rec'd by Steven Lopez on 2/7/17 @ 7:00am 20.9

CONSULTANT INFORMATION













Name: Precision Environmental Inc.
 Address: 36-15A 23rd Street, LIC, NY 11106
 Project Manager: Jon Vafiadis
 PEI Project#: 2181-17-0439

PROJECT INFORMATION

BLDG ID: **Q175**
 BLDG Name: P.S. 175 - QUEENS
 BLDG Address: 64-35 102 STREET
 WO # Queens

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

		(ppb)				(ppb)	
1ST COC Q175 02 FL CLASSROOM 000202 BUBBLER 1  DATE 2-4-17 TIME 1124			I O T M 61	1ST COC Q175 02 FL CLASSROOM 000205 COLD WATER FAUCET 1  DATE 2-4-17 TIME 1148			I O T M 67
1ST COC Q175 02 FL CLASSROOM 000202 COLD WATER FAUCET 1  DATE 2-4-17 TIME 1127			I O T M 62	1ST COC Q175 02 FL CLASSROOM 000206 BUBBLER 1  DATE 2-4-17 TIME 1153			I O T M 68
1ST COC Q175 02 FL CLASSROOM 000203 BUBBLER 1  DATE 2-4-17 TIME 1132			I O T M 63	1ST COC Q175 02 FL CLASSROOM 000206 COLD WATER FAUCET 1  DATE 2-4-17 TIME 1156			I O T M 69
1ST COC Q175 02 FL CLASSROOM 000203 COLD WATER FAUCET 1  DATE 2-4-17 TIME 1135			I O T M 64	1ST COC Q175 02 FL CLASSROOM 000214 BUBBLER 1  DATE 2-4-17 TIME 0715			I O T M 70
1ST COC Q175 02 FL CLASSROOM 000204 BUBBLER 1  DATE 2-4-17 TIME 1140			I O T M 65	1ST COC Q175 02 FL CLASSROOM 000214 COLD WATER FAUCET 1  DATE 2-4-17 TIME 0718			I O T M 71
1ST COC Q175 02 FL CLASSROOM 000204 COLD WATER FAUCET 1  DATE 2-4-17 TIME 1143			I O T M 66	1ST COC Q175 02 FL CLASSROOM 000216 BUBBLER 1  DATE 2-4-17 TIME 0723			I O T M 72

CHAIN OF CUSTODY

Relinquished By: 1 <i>STANLEY GISSBERT</i>	Received By: <i>Demoy 2</i>	Date: <i>2/06/2017</i>	Time: <i>3:30 PM</i>
2 <i>Hussein Alinwande</i>			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name: <i>EMSL</i>	Method of Analysis: <i>200-8</i>
Analyzed By: <i>Eric Gasfill</i>	Date: <i>2/10/2017</i>
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: _____ Sample Size: 250 mL

rec'd by Steven Zapes on 2/7/17 @ 7:00am 2017

CONSULTANT INFORMATION

Name: Precision Environmental Inc.
 Address: 36-15A 23rd Street, LIC, NY 11106
 Project Manager: Jon Vafiadis
 PEI Project#: 2181-17-0439

PROJECT INFORMATION

BLDG ID: Q175
 BLDG Name: P.S. 175 - QUEENS
 BLDG Address: 64-35 102 STREET
 WO # Queens

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

(ppb)	I O T M	(ppb)	I O T M
1ST COC Q175 02 FL CLASSROOM 000216 COLD WATER FAUCET 1 DATE 2-4-17 TIME 0726	73	1ST COC Q175 02 FL CLASSROOM 000222 COLD WATER FAUCET 1 DATE 2-4-17 TIME 0750	79
1ST COC Q175 02 FL CLASSROOM 000220 BUBBLER 1 DATE 2-4-17 TIME 0731	74	1ST COC Q175 02 FL CLASSROOM 000223 BUBBLER 1 DATE 2-4-17 TIME 0755	80
1ST COC Q175 02 FL CLASSROOM 000220 COLD WATER FAUCET 1 DATE 2-4-17 TIME 0734	75	1ST COC Q175 02 FL CLASSROOM 000223 COLD WATER FAUCET 1 DATE 2-4-17 TIME 0758	81
1ST COC Q175 02 FL CLASSROOM 000221 BUBBLER 1 DATE 2-4-17 TIME 0739	76	1ST COC Q175 02 FL CLASSROOM 000232 BUBBLER 1 DATE 2-4-17 TIME 0803	82
1ST COC Q175 02 FL CLASSROOM 000221 COLD WATER FAUCET 1 DATE 2-4-17 TIME 0742	77	1ST COC Q175 02 FL CLASSROOM 000232 COLD WATER FAUCET 1 DATE 2-4-17 TIME 0806	83
1ST COC Q175 02 FL CLASSROOM 000222 BUBBLER 1 DATE 2-4-17 TIME 0744	78	1ST COC Q175 02 FL CLASSROOM 000234 BUBBLER 1 DATE 2-4-17 TIME 0811	84

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1 STEWARTY - AUSEWAT	Denny Butler	2/10/17	12:30 PM
2 Hussein Akinwande			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name: EMSL	Method of Analysis: 200-8
Analyzed By: Eric Gasikil	Date: 2/10/2017
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: Sample Size: 250 mL

rec'd by Steven Zapes on 2/11/17 @ 7:00am 20.9

CONSULTANT INFORMATION

Name: Precision Environmental Inc.
 Address: 36-15A 23rd Street, LIC, NY 11106
 Project Manager: Jon Vafiadis
 PEI Project#: 2181-17-0439

PROJECT INFORMATION

BLDG ID: Q175
 BLDG Name: P.S. 175 - QUEENS
 BLDG Address: 64-35 102 STREET
 WO # Queens

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE	I
OUT-OF-ORDER	O
YELLOW TAG	T
MISCELLANEOUS	M

(ppb)	I O T M	(ppb)	I O T M
1ST COC Q175 02 FL CLASSROOM 000234 COLD WATER FAUCET 1 DATE 2-4-17 TIME 0814	85	1ST COC Q175 02 FL TEACHERS CAFETERIA 000230 COLD WATER FAUCET 1 DATE 2-4-17 TIME 0855	91
1ST COC Q175 02 FL CLASSROOM 000236 BUBBLER 1 DATE 2-4-17 TIME 0819	86	1ST COC Q175 03 FL BOYS BATHROOM 000325 COLD WATER FAUCET 1 DATE 2-4-17 TIME 0900	92
1ST COC Q175 02 FL CLASSROOM 000236 COLD WATER FAUCET 1 DATE 2-4-17 TIME 0822	87	1ST COC Q175 03 FL BOYS BATHROOM 000325 COLD WATER FAUCET 2 DATE 2-4-17 TIME 0903	93
1ST COC Q175 02 FL GIRLS BATHROOM 000212 COLD WATER FAUCET 1 DATE 2-4-17 TIME 0827	88	1ST COC Q175 03 FL CLASSROOM 000301 BUBBLER 1 DATE 2-4-17 TIME 0923	94
1ST COC Q175 02 FL GYMNASIUM 02NDFL BUBBLER 1 DATE 2-4-17 TIME 0832	89	1ST COC Q175 03 FL CLASSROOM 000301 COLD WATER FAUCET 1 DATE 2-4-17 TIME 0928	95
1ST COC Q175 02 FL GYMNASIUM 02NDFL COLD WATER FAUCET 1 DATE 2-4-17 TIME 0838	90	1ST COC Q175 03 FL CLASSROOM 000302 BUBBLER 1 DATE 2-4-17 TIME 0933	96

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1 SHAWAN - AUBURN	Jenny Jordan	2/4/17	3:38 PM
2 Hussein Akinwande	Shawan		
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name: EMSL	Method of Analysis: 200.8
Analyzed By: Eric Gaskill	Date: 2/10/2017
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Time: 3:38 PM
	Preservative:
	Sample Size: 250 mL

rec'd by Steven Lopez on 2/17/17 @ 7:00am 20.9

CONSULTANT INFORMATION

Name: Precision Environmental Inc.
 Address: 36-15A 23rd Street, LIC, NY 11106
 Project Manager: Jon Vafiadis
 PEI Project#: 2181-17-0439

PROJECT INFORMATION

BLDG ID: Q175
 BLDG Name: P.S. 175 - QUEENS
 BLDG Address: 64-35 102 STREET
 WO # Queens

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

	(ppb)			(ppb)	
1ST COC Q175 03 FL CLASSROOM 000302 COLD WATER FAUCET 1 DATE 2-4-17 TIME 0935		I O T M	97	1ST COC Q175 03 FL CLASSROOM 000306 COLD WATER FAUCET 1 DATE 2-4-17 TIME 1000	I O T M b3
1ST COC Q175 03 FL CLASSROOM 000303 BUBBLER 1 DATE 2-4-17 TIME 0940		I O T M	98	1ST COC Q175 03 FL CLASSROOM 000320 BUBBLER 1 DATE 2-4-17 TIME 1005	I O T M b4
1ST COC Q175 03 FL CLASSROOM 000303 COLD WATER FAUCET 1 DATE 2-4-17 TIME 0943		I O T M	99	1ST COC Q175 03 FL CLASSROOM 000320 COLD WATER FAUCET 1 DATE 2-4-17 TIME 1008	I O T M b5
1ST COC Q175 03 FL CLASSROOM 000304 BUBBLER 1 DATE 2-4-17 TIME 0948		I O T M	b0	1ST COC Q175 03 FL CLASSROOM 000321 BUBBLER 1 DATE 2-4-17 TIME 1013	I O T M b6
1ST COC Q175 03 FL CLASSROOM 000304 COLD WATER FAUCET 1 DATE 2-4-17 TIME 0951		I O T M	b1	1ST COC Q175 03 FL CLASSROOM 000321 COLD WATER FAUCET 1 DATE 2-4-17 TIME 1018	I O T M b7
1ST COC Q175 03 FL CLASSROOM 000306 BUBBLER 1 DATE 2-4-17 TIME 0956		I O T M	b2	1ST COC Q175 03 FL CLASSROOM 000322 BUBBLER 1 DATE 2-4-17 TIME 1023	I O T M b8

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1 <i>S. Hussain</i>	<i>Jerry Sabra</i>	2/6/17	3:30p
2 Hussain	Alcinwande		
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name: EMSL	Method of Analysis: 2008
Analyzed By: Eric Gaskill	Date: 2/10/2017
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative: Sample Size: 250 mL

rec'd by Steve Jones on 2/7/17 @ 7:00am 20.9

CONSULTANT INFORMATION






Name: Precision Environmental Inc.
 Address: 36-15A 23rd Street, LIC, NY 11106
 Project Manager: Jon Vafiadis
 PEI Project#: 2181-17-0439

PROJECT INFORMATION

BLDG ID: Q175
 BLDG Name: P.S. 175 - QUEENS
 BLDG Address: 64-35 102 STREET
 WO # Queens

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

	(ppb)			(ppb)	
1ST COC Q175 03 FL CLASSROOM 000322 COLD WATER FAUCET 1  DATE 2-4-17 TIME 1028		I O T M	109		I O T M
1ST COC Q175 03 FL CLASSROOM 000324 BUBBLER 1  DATE 2-4-17 TIME 1033		I O T M	110		I O T M
1ST COC Q175 03 FL CLASSROOM 000324 COLD WATER FAUCET 1  DATE 2-4-17 TIME 1038		I O T M	111		I O T M
1ST COC Q175 03 FL GIRLS BATHROOM 000305 COLD WATER FAUCET 1  DATE 2-4-17 TIME 1043		I O T M	112		I O T M
1ST COC Q175 03 FL GIRLS BATHROOM 000305 COLD WATER FAUCET 2  DATE 2-4-17 TIME 1048		I O T M	113		I O T M
		I O T M			I O T M

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1 SHAWAN HUSSEIN	Jenny	2/10/17	3:33 PM
2 Hussein Alinwande			
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name: EMSL	Method of Analysis: 200.8
Analyzed By: Eric Gaskill	Date: 2/10/2017
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Time: 3:33 PM
	Preservative:
	Sample Size: 250 mL

rec'd by Aeron Jones on 2/17/17 @ 7:20am 20.9