



Elizabeth A. Rose
Deputy Chancellor
Division of Operations

52 Chambers Street
New York, NY 10007

212 374 7868 Tel
212 374 5588 Fax

December 30, 2016

Dear Families and Staff:

This is a follow up to my December 19 letter outlining the additional measures the New York City Department of Education (DOE) is taking to ensure that the water in New York City schools is safe for students and staff.

On December 2, 2016, every potential source of water for drinking or preparing food at **P.S. 124 Silas B. Dutcher** (515 4th AVENUE BROOKLYN, NY 11215) was tested for lead. The laboratory results showed elevated levels of lead in **8 of the 38 samples** of water taken and tested from outlets in the building. A more detailed letter related to the testing for lead at P.S. 124 is attached, and complete test results are posted on the DOE website.

In any building where lead test results show even one water outlet above the action level of 15 parts per billion, the DOE will implement its standard response protocol, under which it removes any such outlet from service, flushes all or part of the system to eliminate water sitting in pipes overnight, replaces equipment and re-tests after the equipment is replaced.

Each affected fixture at P.S. 124 will remain out of service until it is remediated and future testing shows that the water does not have an elevated level of lead. The custodial staff will also continue to flush the P.S. 124 water systems on Monday mornings before school starts in order to eliminate water that has been stagnant in pipes over the weekend and to ensure safe drinking water is available for students and staff.

Please visit <http://schools.nyc.gov/AboutUs/schools/watersafety.htm> to learn more about the robust protocol we use to ensure the safety of drinking water in each and every school, as well as to look up water test results for their child's school.

We will keep you updated on the remediation work at P.S. 124, and thank you for your patience and support.

Sincerely yours,

A handwritten signature in black ink that reads 'Elizabeth A. Rose'. The signature is fluid and cursive, with the first letters of the first and last names being capitalized and prominent.

Elizabeth A. Rose

A NOTICE TO PARENTS, GUARDIANS, AND STAFF
P.S. 124 SILAS B. DUTCHER
515 4TH AVENUE BROOKLYN, NY 11215
LEAD TESTING OF SCHOOL DRINKING WATER
DECEMBER 30, 2016

Safe and healthy school environments can foster healthy and successful children. To protect public health, the Public Health Law and New York State Health Department (NYSDOH) regulations require that all public schools and boards of cooperative educational services (BOCES) test lead levels in water from every outlet that is being used, or could potentially be used, for drinking or cooking. If lead is found at any water outlet at levels above 15 parts per billion (ppb), which is equal to 15 micrograms per liter ($\mu\text{g/L}$), the NYSDOH requires that the school take action to reduce the exposure to lead.

What is first draw testing of school drinking water for lead?

The “on-again, off-again” nature of water use at most schools can raise lead levels in school drinking water. Water that remains in pipes overnight, over a weekend, or over vacation periods stays in contact with lead pipes or lead solder and, as a result, could contain higher levels of lead. This is why schools are required to collect a sample after the water has been sitting in the plumbing system for a certain period of time. This “first draw” sample is likely to show higher levels of lead for that outlet than what you would see if you sampled after using the water continuously. However, even if the first draw sample does not reflect what you would see with continuous usage, it is still important because it can identify outlets that have elevated lead levels.

What are the results of the first draw testing?

Samples Collected on 12/02/2016				
Floor	Function/ Space	Room	Fixture Type	Sample Results
BS	Gymnasium	B06	Hose Bib 1	62.3 ppb
BS	Gymnasium	B06	Hose Bib 2	335 ppb
MZ	Exterior	4 th Ave	Hose Bib 1	26.3 ppb
01	Boys Bathroom	108T	Cold Water Faucet 1	20.5 ppb
01	Girls Bathroom	104F	Hose Bib 1	16.5 ppb
01	Medical Office	104G	Cold Water Faucet 1	34.3 ppb
02	Classroom	202	Bubbler 1	276 ppb
02	Girls Bathroom	204D	Hose Bib 1	897 ppb

What is being done in response to the results?

All drinking and cooking water outlets that tested with lead levels above the action level (15 ppb) were removed from service, and are being remediated.

What are the health effects of lead?

Lead is a metal that can harm children and adults when it gets into their bodies. Lead is a known neurotoxin, particularly harmful to the developing brain and nervous system of children under 6 years old. Lead can harm a young child's growth, behavior, and ability to learn. Lead exposure during pregnancy

may contribute to low birth weight and developmental delays in infants. There are many sources of lead exposure in the environment, and it is important to reduce all lead exposures as much as possible. Water testing helps identify and correct possible sources of lead that contribute to exposure from drinking water.

What are the other sources of lead exposure?

Lead is a metal that has been used for centuries for many purposes, resulting in widespread distribution in the environment. Major sources of lead exposure include lead-based paint in older housing, and lead that built up over decades in soil and dust due to historical use of lead in gasoline, paint, and manufacturing. Lead can also be found in a number of consumer products, including certain types of pottery, pewter, brass fixtures, foods, plumbing materials, and cosmetics. Lead seldom occurs naturally in water supplies but drinking water could become a possible source of lead exposure if the building's plumbing contains lead. The primary source of lead exposure for most children with elevated blood-lead levels is lead-based paint.

Should your child be tested for lead?

The risk to an individual child from past exposure to elevated lead in drinking water depends on many factors; for example, a child's age, weight, amount of water consumed, and the amount of lead in the water. Children may also be exposed to other significant sources of lead including paint, soil and dust. Since blood lead testing is the only way to determine a child's blood lead level, parents should discuss their child's health history with their child's physician to determine if blood lead testing is appropriate. Pregnant women or women of childbearing age should also consider discussing this matter with their physician.

Additional Resources

For more information regarding the testing program or sampling results go to:

<http://schools.nyc.gov/AboutUs/schools/watersafety.htm>

For information about lead in school drinking water, go to:

http://www.health.ny.gov/environmental/water/drinking/lead/lead_testing_of_school_drinking_water.htm

<http://www.p12.nysed.gov/facplan/LeadTestinginSchoolDrinkingWater.html>

For information about NYS Department of Health Lead Poisoning Prevention, go to:

<http://www.health.ny.gov/environmental/lead/>

For more information on blood lead testing and ways to reduce your child's risk of exposure to lead, see "What Your Child's Blood Lead Test Means":

<http://www.health.ny.gov/publications/2526/> (available in ten languages).



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Michael Parpounas
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106**

12/9/2016

Phone: (718) 383-2626
Fax: (718) 383-7780

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/5/2016. The results are tabulated on the attached data pages for the following client designated project:

K124 / P.S. 124 - Brooklyn / 515 4 Avenue, Brooklyn, NY / 2181-16-0364

The reference number for these samples is EMSL Order #011608271. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 187

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011608271

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Michael Parpounas**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 12/05/16 7:00 AM

Project: K124 / P.S. 124 - Brooklyn / 515 4 Avenue, Brooklyn, NY / 2181-16-0364

Analytical Results

Client Sample Description 1CK124BSBB000B05.1F-001 **Collected:** 12/2/2016 **Lab ID:** 0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.02	1.00	µg/L	12/5/2016	CB	12/5/2016	BB

Client Sample Description 1CK124BSGB000B15.1F-003 **Collected:** 12/2/2016 **Lab ID:** 0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.23	1.00	µg/L	12/5/2016	CB	12/5/2016	BB

Client Sample Description 1CK124BSGB000B15.2F-004 **Collected:** 12/2/2016 **Lab ID:** 0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.91	1.00	µg/L	12/5/2016	CB	12/5/2016	BB

Client Sample Description 1CK124BSGB000B15.3F-005 **Collected:** 12/2/2016 **Lab ID:** 0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.16	1.00	µg/L	12/5/2016	CB	12/5/2016	BB

Client Sample Description 1CK124BSGY000B06.1B-006 **Collected:** 12/2/2016 **Lab ID:** 0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.86	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK124BSGY000B06.2B-007 **Collected:** 12/2/2016 **Lab ID:** 0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.15	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK124BSGY000B06.3B-008 **Collected:** 12/2/2016 **Lab ID:** 0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.32	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011608271
 CustomerID: PCIS63
 CustomerPO:
 ProjectID:

Attn: **Michael Parpounas**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 12/05/16 7:00 AM

Project: K124 / P.S. 124 - Brooklyn / 515 4 Avenue, Brooklyn, NY / 2181-16-0364

Analytical Results

Client Sample Description 1CK124BSGY000B06.4B-009 **Collected:** 12/2/2016 **Lab ID:** 0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.17	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK124BSGY000B06.1H-010 **Collected:** 12/2/2016 **Lab ID:** 0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	62.3	1.00	µg/L	12/7/2016	LY	12/7/2016	EG

Client Sample Description 1CK124BSGY000B06.2H-011 **Collected:** 12/2/2016 **Lab ID:** 0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	335	10.0	µg/L	12/7/2016	LY	12/8/2016	EG

Client Sample Description 1CK124BSKI000B10.1F-012 **Collected:** 12/2/2016 **Lab ID:** 0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.40	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK124BSKI000B10.2F-013 **Collected:** 12/2/2016 **Lab ID:** 0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.52	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK124BSKI000B10.3F-014 **Collected:** 12/2/2016 **Lab ID:** 0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.09	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK124MZEX4THAVE.1H-015 **Collected:** 12/2/2016 **Lab ID:** 0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	26.3	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011608271

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Michael Parpounas**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 12/05/16 7:00 AM

Project: K124 / P.S. 124 - Brooklyn / 515 4 Avenue, Brooklyn, NY / 2181-16-0364

Analytical Results

Client Sample Description 1CK12401BB00104E.1F-016 **Collected:** 12/2/2016 **Lab ID:** 0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.24	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK12401BB00104E.1H-017 **Collected:** 12/2/2016 **Lab ID:** 0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	14.0	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK12401BB00108T.1F-019 **Collected:** 12/2/2016 **Lab ID:** 0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	20.5	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK12401CR000107.1B-021 **Collected:** 12/2/2016 **Lab ID:** 0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.86	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK12401CR000107.1F-022 **Collected:** 12/2/2016 **Lab ID:** 0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.78	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK12401CR000108.1B-023 **Collected:** 12/2/2016 **Lab ID:** 0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.71	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK12401CR000108.1F-024 **Collected:** 12/2/2016 **Lab ID:** 0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.21	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011608271
 CustomerID: PCIS63
 CustomerPO:
 ProjectID:

Attn: **Michael Parpounas**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 12/05/16 7:00 AM

Project: K124 / P.S. 124 - Brooklyn / 515 4 Avenue, Brooklyn, NY / 2181-16-0364

Analytical Results

Client Sample Description 1CK12401GB00104F.1F-025 **Collected:** 12/2/2016 **Lab ID:** 0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.87	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK12401GB00104F.1H-026 **Collected:** 12/2/2016 **Lab ID:** 0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	16.5	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK12401HA000102.1B-027 **Collected:** 12/2/2016 **Lab ID:** 0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.43	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK12401HA000102.1F-028 **Collected:** 12/2/2016 **Lab ID:** 0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK12401MO00104G.1F-029 **Collected:** 12/2/2016 **Lab ID:** 0026

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	34.3	1.00	µg/L	12/7/2016	LY	12/7/2016	EG

Client Sample Description 1CK12401OF00106A.1F-030 **Collected:** 12/2/2016 **Lab ID:** 0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.54	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK12402CR000202.1B-033 **Collected:** 12/2/2016 **Lab ID:** 0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	276	5.00	µg/L	12/5/2016	CB	12/6/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011608271
 CustomerID: PCIS63
 CustomerPO:
 ProjectID:

Attn: **Michael Parpounas**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 12/05/16 7:00 AM

Project: K124 / P.S. 124 - Brooklyn / 515 4 Avenue, Brooklyn, NY / 2181-16-0364

Analytical Results

Client Sample Description 1CK12402CR000202.1F-034 **Collected:** 12/2/2016 **Lab ID:** 0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.39	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK12402GB00204D.1F-035 **Collected:** 12/2/2016 **Lab ID:** 0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.90	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK12402GB00204D.1H-036 **Collected:** 12/2/2016 **Lab ID:** 0031

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	897	50.0	µg/L	12/7/2016	LY	12/8/2016	EG

Client Sample Description 1CK12402HA000202.1B-037 **Collected:** 12/2/2016 **Lab ID:** 0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK12402HA000202.1F-038 **Collected:** 12/2/2016 **Lab ID:** 0033

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.02	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK12402OF00206A.1F-039 **Collected:** 12/2/2016 **Lab ID:** 0034

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.65	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK12402TC000204.1F-040 **Collected:** 12/2/2016 **Lab ID:** 0035

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.10	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011608271

CustomerID: PCIS63

CustomerPO:

ProjectID:

Attn: **Michael Parpounas**
Precision Environmental
36-15 A 23rd Street
2nd floor
Long Island City, NY 11106

Phone: (718) 383-2626
 Fax: (718) 383-7780
 Received: 12/05/16 7:00 AM

Project: K124 / P.S. 124 - Brooklyn / 515 4 Avenue, Brooklyn, NY / 2181-16-0364

Analytical Results

Client Sample Description 1CK12403HA000302.1B-042 **Collected:** 12/2/2016 **Lab ID:** 0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK12403HA000302.1F-043 **Collected:** 12/2/2016 **Lab ID:** 0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.44	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Client Sample Description 1CK12403OF00306A.1F-044 **Collected:** 12/2/2016 **Lab ID:** 0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.01	1.00	µg/L	12/5/2016	CB	12/6/2016	BB

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

CONSULTANT INFORMATION

Name: Precision Environmental Inc.
 Address: 36-15A 23rd Street, LIC, NY 11106
 Project Manager: Michael Parpounas
 PEI Project#: 2181-16-0364

EMSL MANHATTAN LAB RECEIVED
 16 DEC -2 PM 4: 16

PROJECT INFORMATION

BLDG ID: K124
 BLDG Name: P.S. 124 - BROOKLYN
 Address: 515 4 AVENUE, BROOKLYN, NY

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

(ppb)	I O T M	(ppb)	I O T M
1ST COC k124 BS FL BOYS BATHROOM 000B05 COLD WATER FAUCET 1 DATE 12/02/16 TIME 02:04	1	1ST COC k124 BS FL GYMNASIUM 000B06 BUBBLER 3 DATE 12/02/16 TIME 02:14	7
1ST COC k124 BS FL GIRLS BATHROOM 000B15 COLD WATER FAUCET 1 DATE 12/02/16 TIME 02:05	2	1ST COC k124 BS FL GYMNASIUM 000B06 BUBBLER 4 DATE 12/02/16 TIME 02:15	8
1ST COC k124 BS FL GIRLS BATHROOM 000B15 COLD WATER FAUCET 2 DATE 12/02/16 TIME 02:06	3	1ST COC k124 BS FL GYMNASIUM 000B06 HOSE BIB 1 DATE 12/02/16 TIME 02:18	9
1ST COC k124 BS FL GIRLS BATHROOM 000B15 COLD WATER FAUCET 3 DATE 12/02/16 TIME 02:07	4	1ST COC k124 BS FL GYMNASIUM 000B06 HOSE BIB 2 DATE 12/02/16 TIME 02:22	10
1ST COC k124 BS FL GYMNASIUM 000B06 BUBBLER 1 DATE 12/02/16 TIME 02:12	5	1ST COC k124 BS FL KITCHEN 000B10 COLD WATER FAUCET 1 DATE 12/02/16 TIME 02:25	11
1ST COC k124 BS FL GYMNASIUM 000B06 BUBBLER 2 DATE 12/02/16 TIME 02:13	6	1ST COC k124 BS FL KITCHEN 000B10 COLD WATER FAUCET 2 DATE 12/02/16 TIME 02:26	12

EMSL MANHATTAN LAB RECEIVED
 16 DEC -2 PM 4: 14

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1 Gibson Aguilera	Andre	12/2/2016	9:30
2 Andre	Andre	12/2/16	4:14 PM
3	AM COURIER	12/2/16	8:30 pm

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name:	Method of Analysis:
Analyzed By:	Date:
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Time:
	Preservative:
	Sample Size: 250 mL

Rec'd Attn Inf 12/5/16 231 7:00am

011608271

CONSULTANT INFORMATION

Name: Precision Environmental Inc.
 Address: 36-15A 23rd Street, LIC, NY 11106
 Project Manager: Michael Parpounas
 PEI Project#: 2181-16-0364

PROJECT INFORMATION

BLDG ID: K124
 BLDG Name: P.S. 124 - BROOKLYN
 Address: 515 4 AVENUE, BROOKLYN, NY
 WO #

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE	I
OUT-OF-ORDER	O
YELLOW TAG	T
MISCELLANEOUS	M

(ppb)				(ppb)			
1ST COC K124 BS FL KITCHEN 000B10 COLD WATER FAUCET 3 DATE 12/02/16 TIME 02:28		I O T M	13	1ST COC K124 01 FL CLASSROOM 000107 COLD WATER FAUCET 1 DATE 12/02/16 TIME 02:56		I O T M	19
1ST COC K124 MZ FL EXTERIOR 4THAVE HOSE BIB 1 DATE 12/02/16 TIME 02:35		I O T M	14	1ST COC K124 01 FL CLASSROOM 000108 BUBBLER 1 DATE 12/02/16 TIME 03:00		I O T M	20
1ST COC K124 01 FL BOYS BATHROOM 00104E COLD WATER FAUCET 1 DATE 12/02/16 TIME 02:40		I O T M	15	1ST COC K124 01 FL CLASSROOM 000108 COLD WATER FAUCET 1 DATE 12/02/16 TIME 03:01	16 DEC -2	I O T M	21
1ST COC K124 01 FL BOYS BATHROOM 00104E HOSE BIB 1 DATE 12/02/16 TIME 02:43		I O T M	16	1ST COC K124 01 FL GIRLS BATHROOM 00104F COLD WATER FAUCET 1 DATE 12/02/16 TIME 03:05	PH 4:16	I O T M	22
1ST COC K124 01 FL BOYS BATHROOM 00108T COLD WATER FAUCET 1 DATE 12/02/16 TIME 02:50		I O T M	17	1ST COC K124 01 FL GIRLS BATHROOM 00104F HOSE BIB 1 DATE 12/02/16 TIME 03:06	EMSL MAIL ROOM LAB RECEIVED	I O T M	23
1ST COC K124 01 FL CLASSROOM 000107 BUBBLER 1 DATE 12/02/16 TIME 02:54		I O T M	18	1ST COC K124 01 FL HALLWAY 000102 BUBBLER 1 DATE 12/02/16 TIME 03:10		I O T M	24

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1 <i>George Adewumi H</i>	<i>Andrea</i>	12/2/2016	9:30
2 <i>Andrea</i>	<i>Yunice</i>	12/2/16	4:16 PM
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name:	Method of Analysis:	
Analyzed By:	Date:	Time:
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Preservative:	Sample Size: 250 mL

011608271

CONSULTANT INFORMATION

Name: Precision Environmental Inc.
 Address: 36-15A 23rd Street, LIC, NY 11106
 Project Manager: Michael Parpounas
 PEI Project#: 2181-16-0364

PROJECT INFORMATION

BLDG ID: K124
 BLDG Name: P.S. 124 - BROOKLYN
 Address: 515 4 AVENUE, BROOKLYN, NY
 WO #

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE	I
OUT-OF-ORDER	O
YELLOW TAG	T
MISCELLANEOUS	M

(ppb)	I	O	T	M	(ppb)	I	O	T	M
1ST COC K124 01 FL HALLWAY 000102 COLD WATER FAUCET 1 DATE 12/2/16 TIME 03:11				25	1ST COC K124 02 FL GIRLS BATHROOM 00204D HOSE BIB 1 DATE 12/2/16 TIME 03:40				31
1ST COC K124 01 FL MEDICAL OFFICE 00104G COLD WATER FAUCET 1 DATE 12/2/16 TIME 03:15				26	1ST COC K124 02 FL HALLWAY 000202 BUBBLER 1 DATE 12/2/16 TIME 03:44				32
1ST COC K124 01 FL OFFICE 00106A COLD WATER FAUCET 1 DATE 12/2/16 TIME 03:18				27	1ST COC K124 02 FL HALLWAY 000202 COLD WATER FAUCET 1 DATE 12/2/16 TIME 03:45				33
1ST COC K124 02 FL CLASSROOM 000202 BUBBLER 1 DATE 12/2/16 TIME 03:20				28	1ST COC K124 02 FL OFFICE 00206A COLD WATER FAUCET 1 DATE 12/2/16 TIME 03:50	16 DEC - 2 PM 4:11			38 34
1ST COC K124 02 FL CLASSROOM 000202 COLD WATER FAUCET 1 DATE 12/2/16 TIME 03:22				29	1ST COC K124 02 FL TEACHERS CAFETERIA 000204 COLD WATER FAUCET 1 DATE 12/2/16 TIME 03:55	EMSL MAIL ROOM RECEIVED			35
1ST COC K124 02 FL GIRLS BATHROOM 00204D COLD WATER FAUCET 1 DATE 12/2/16 TIME 03:38				30	1ST COC K124 03 FL HALLWAY 000302 BUBBLER 1 DATE 12/2/16 TIME 04:00				36

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1 George Adams H	Andreana	12/2/2016	9:30
2 Andreana	Andreana	12/2/16	4:14 PM
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name:	Method of Analysis:
Analyzed By:	Date:
Note: No sample submitted if "I", "O", "T", or "M" check-marked.	Time:
	Preservative:
	Sample Size: 250 mL

011608271

CONSULTANT INFORMATION



Name: Precision Environmental Inc.
 Address: 36-15A 23rd Street, LIC, NY 11106
 Project Manager: Michael Parpounas
 PEI Project#: 2181-16-0364

PROJECT INFORMATION

BLDG ID: K124
 BLDG Name: P.S. 124 - BROOKLYN
 Address: 515 4 AVENUE, BROOKLYN, NY
 WO #

NON-SAMPLABLE OUTLET LEGEND

INACCESSIBLE I
 OUT-OF-ORDER O
 YELLOW TAG T
 MISCELLANEOUS M

(ppb)			(ppb)	
1ST COC K124 03 FL HALLWAY 000302 COLD WATER FAUCET 1  DATE 12/02/16 TIME 04:01		I O T M 37		I O T M
1ST COC K124 03 FL OFFICE 00306A COLD WATER FAUCET 1  DATE 12/02/16 TIME 04:05		I O T M 38		I O T M
		I O T M		I O T M
		I O T M	16 DEC - 1 PH 4: 14 EMSL NATIONAL LAB RECEIVED	I O T M
		I O T M		I O T M
		I O T M		I O T M

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:
1 <i>George Adamski H</i>			
2	<i>Lumina</i>	12/2/16	4:14pm
3			

INSTRUCTIONS TO LABORATORY: Please email results to:

LABORATORY INFORMATION

Laboratory Name:	Method of Analysis:	
Analyzed By:	Date:	Time:
Note: No sample submitted if "I", "O", "T", or "M" check-marked	Preservative:	Sample Size: 250 mL